

Fukushima Daiichi Nuclear Accident;

based on the Final Report of Atomic Energy Society of Japan

Prof. Naoto Sekimura, Ph.D

Department of Nuclear Engineering and Management

The University of Tokyo


Contents

- 1. The AESJ Investigation Committee on the Fukushima Daiichi Accident***
- 2. Overview of the Fukushima Daiichi Accident***
- 3. (Events at Other NPS)***
- 4. Overview of “Accident Analysis and Issues”***
- 5. Root Cause Analysis of the Accident***
- 6. Recommendations by the AESJ Committee***

Objectives of the AESJ Investigation Committee on the Fukushima Daiichi Accident

- **The AESJ, as a professional and academic organization of nuclear experts and scientists, is responsible to identify the underlying and root causes of the TEPCO's Fukushima Daiichi NPS accident through technical surveys and analyses, and to offer solutions for ensuring and enhancing nuclear safety.**
 - **The Fundamental Concept on Nuclear Safety has also been developed to meet this objective.**
 - **Factors on why this nuclear disaster could not be prevented in connection to the organizational issues of the AESJ have also been discussed.**
 - **The AESJ is committed to promote organizational and operational reforms of the nuclear community in Japan and to enhance nuclear safety research, etc., on the basis of the recommendations in the Final Report.**

Survey Methods of the Investigation Committee




Structure of the AESJ Final Report

Chapter	Contents	Notes
1	Introduction	
2	Overview of Nuclear Power Stations	Confirmation of facts
3	Overview of the Accident at the Fukushima Daiichi Nuclear Power Station	
4	Overview of Events at Other Nuclear Power Stations	
5	Off-site Response	
6	Accident Analysis and Issues	Accident analysis
7	Analysis & Issues on Nuclear Safety System	
8	Root Causes of the Accident and Recommendations	Root cause analysis and recommendations
9	Post-Accident Management in Progress	Analysis of issues related to decommissioning
Appendix	1) List of the Committee Members; 2) List of the Committee activities; 3) List of Abbreviations	Others
Web Page	Glossary of terms, links to related reference sources (Japanese)	

Key Approaches for the AESJ Surveys

- **The primary purpose of ensuring safety of nuclear facilities is “The Protection of People and the Environment” from radiation consequences.**
- From this perspective, surveys on the causes for radioactive material release from nuclear facilities and issues in accident management for the protection of local residents from exposure have been conducted.
- Multi-disciplinary analyses have been made for clarifying the root causes of the accident in a typical huge and complex system.
- In addition to technical & professional approach, reformation of the AESJ organization has been discussed.


Fukushima Daiichi Nuclear Power Plant operated by TEPCO




Status of Fukushima Daiichi Units 1-6

	Unit 1	Unit 2	Unit 3	Unit 4	Unit 5	Unit 6
Reactor Type	BWR-3	BWR-4			BWR-5	
PCV Type	Mark-I			Mark-II		
Start of Operation	1971	1974	1976	1978	1978	1979
Electric Output (MW)	460	784			1100	
Thermal Output (MW)	1380	2381			3293	
Status on March 11 before the Earthquake	Full Power Operation			Outage		
				All fuel removed	RPV top lid closed	


BWR-3



BWR-4




BWR-5



Summary of Damages in NPSs

<u>Site</u>	<u>Units</u>	<u>Off-site ac Power</u>	<u>E. D/G</u>	<u>dc Power</u>	<u>Heat Sink</u>	<u>Switchyard</u>	<u>Nuclear Fuels</u>
Fukushima Daiichi	<u>1</u>		All Lost	Lost	Lost	Lost	Melt-down
	<u>2</u>	275kV,	All Lost	Lost	Lost	Lost	Melt-down
	<u>3</u>	All Lost	All Lost	Shortly L.	Lost	Lost	Melt-down
	<u>4</u>	66kV,	All Lost	Lost	Lost	Lost	Sound
	<u>5</u>	All Lost	All Lost	Available	Lost	Lost	Sound
	<u>6</u>		1/3 Available	Available	Lost	Available	Sound
Fukushima Daini	<u>1</u>	500kV,	All Lost	Available	Lost	Available	Sound
	<u>2</u>	1/2 Available	Available	Available	Lost	Available	Sound
	<u>3</u>	66kV,	Available	Available	1/2 Usable	Available	Sound
	<u>4</u>	All Lost.	Available	Available	Lost	Available	Sound
Onagawa	<u>1</u>	275kV,	Available	Available	Usable	Available	Sound
	<u>2</u>	1/4 Available	Available	Available	1/2 Usable	Available	Sound
	<u>3</u>	66kV, All Lost	Available	Available	Usable	Available	Sound
Tokai-Daini	<u>1</u>	275kV/154kV, All Lost	Available	Available	Usable	Available	Sound

Tsunami Flood in Units 1-4




Assumption of Tsunami Height was Max. 6.1 m before the Accident.

Flood Route to the Basement of Turbine Building

- ① Air Supply Louver for Emergency Diesel Generator
- ② Turbine Building Entrance
- ③ Component Hatch

Influence of the Tsunami Flooding on Electric Power Distribution Systems



TEPCO, Fukushima Nuclear Accidents Investigation Report, Attachment 7-3.



Source: TEPCO

- All AC power (high voltage line of 6.9kV, low voltage line of 480 V and 120 V) were lost in Units 1, 2, 3, 4 and 5.
- Main DC bus (125 V) was lost in Units 1, 2 and 4.

Influence of Tsunami on Ultimate Heat Sink

- ✓ Seawater Pumps for Ultimate Heat Sink were lost in all the 6 units.



Possibility of Damage of Components by the Earthquake

Key points discussed in the Diet Investigation Report

Likelihood that SR valves in Unit 1 was not functioning at the time earthquake occurred - if so, a minor LOCA may have occurred in Unit 1 by the seismic ground motion.

Results of Data Analysis by the AESJ Investigation Committee

- (1) Reactor pressure was maintained below SR valve pressure by IC activation in Unit 1.
- (2) Insignificant increase in PCV internal pressure verified by suspended drywell cooler.
- (3) No leakage exceeding predetermined limit stipulated in safety regulations; **no LOCA.**

Fundamental Safety Functions for Light Water Reactors


Shutting Down by interrupting fission chain reaction through insertion of control rods

Cooling Down the core through continuous water injection and circulation

Confining radioactive materials inside the boundary (RPV and PCV)

Decay Power and Radioactive Materials in Units 1, 2 and 3

Decay Heat after the Shut-down



Source Term just after the Shut-down

Unit 1

I-131 : 1.9×10^{18} Bq

Cs-137 : 2.0×10^{17} Bq

Unit 2

I-131 : 2.7×10^{18} Bq


Cs-137 : 2.4×10^{17} Bq

Unit 3


I-131 : 2.7×10^{18} Bq

Cs-137 : 2.4×10^{17} Bq


Operational Procedure of BWR under Emergency



Available Safety Systems after the Tsunami in Unit 1



Isolation Condenser (IC) in Unit 1



Core damage in Unit 1 progressed in a short period of time after the tsunami. The status of the IC, which is used to cool the reactor in the initial stages after shutdown, have affected the event progression.

Water Level in Unit 1







Figure 1 Fuel range water level indicator






Cooling Reactor Core in Unit 1


- At 2:45 on March 12, RPV pressure was determined to be 0.8 Mpa
- Around 4AM on March 12, fire engine brought fresh water and injected water into reactor core through Fire Prevention (FP) line.
 - The connection between FP line and reactor core was installed for accident management on 1990's.
 - The connector between FP line and fire engine was prepared to enhance fire prevention capacity after Chuetsu-oki earthquake.
- Two fire engine was used to pump water directly from water tank, and 80 t of fresh water was injected until 14:53 on March 12.
- At 19:02, after the tank dried off, seawater in back wash valve pit for Unit 3 was injected into Unit 1 reactor core



Estimated Parameters in Unit 1



Some measured values used for model justification are also shown.




Generation of Hydrogen in Unit 1




Zr-H₂O reaction at high temperature is main source of H₂.

Release Rates of Fission Products in Various Chemical Forms in Unit 1

FP Release Ratio in log scale



Distribution of CsI and CsOH in Various Location in Unit 1 (MAAP code)



Groups of Radionuclides from Nuclear Fuel


<i>Group #</i>	<i>Designation</i>	<i>Elements</i>
1	Noble Gases	Xe, Kr
2	Halogens	I, Br
3	Alkali Metals	Cs, Rb
4	Tellurium Group	Te, Sb, Se
5	Barium, Strontium	Ba, Sr
6	Noble Metals	Ru, Rh, Pd, Mo, Tc, Co
7	Lanthanides	La, Zr, Nd, Eu, Nb, Pm, Pr, Sm, Y, Cm, Am
8	Cerium Group	Ce, Pu, Np

Released Amount of Radio-active Nuclide Estimated by the MELCORE code

(Bq)

Nuclide	Unit 1	Unit 2	Unit 3
Xe-133	1.6×10^{18}	3.3×10^{18}	4.3×10^{18}
I-131	4.8×10^{16}	1.9×10^{17}	$1.4 \times 10^{16} \sim 1.0 \times 10^{17}$
Cs-134	1.2×10^{15}	7.1×10^{15}	$2.22 \times 10^{13} \sim 6.7 \times 10^{15}$
Cs-137	9.7×10^{14}	6.3×10^{15}	$1.3 \times 10^{12} \sim 5.8 \times 10^{15}$
Sr-89	6.9×10^{14}	1.2×10^{16}	$4.5 \times 10^{13} \sim 2.2 \times 10^{14}$
Ba-140	1.0×10^{15}	1.9×10^{16}	$2.7 \times 10^{14} \sim 3.55 \times 10^{14}$
Te-132	4.6×10^{16}	8.3×10^{16}	$2.8 \times 10^{16} \sim 3.3 \times 10^{16}$
Ru-103	8.82×10^7	6.8×10^{10}	$3.2 \times 10^9 \sim 4.0 \times 10^9$
Pu-241	6.3×10^6	3.0×10^8	$3.0 \times 10^5 \sim 2.6 \times 10^7$
Cm-242	2.4×10^8	7.51×10^9	$2.1 \times 10^9 \sim 6.7 \times 10^9$


Hydrogen Explosion in Unit 1 at 15:36 on March 12, 2011



Reactor building




Reactor building

Location of Possible Gas Release from Mark-I PCV to the Reactor Building




(Source) Example of Onagawa Power Station of Tohoku Electric Power Co., Inc.
(The photo of the top flange is from Tokyo Electric Power Co., Inc.)

Estimated Parameters in Unit 1




Some measured values used for model justification are also shown.


Elementary Models in the Accident Analysis Code



Primary System Modeling



Containment Modeling






Lower Plenum Modeling

Example of the MAAP code


MCCI: Molten Core Concrete Interaction in Unit 1

Estimated Ablation Depth


- ✓ MAAP/DECOMP code
0.65 m
- ✓ COCO code
0.45 m : Basement
0.38 m : Side Wall



Available Safety Systems after the Tsunami in Unit 2



Available Safety Systems after the Tsunami in Unit 3



Cooling Reactor Core in Unit 3


- DC power was available in Unit 3, so that RCIC and HPCI could be used for high pressure water injection. In addition, diesel driven fire pump (DD/FP) was active, so that FP system could be used for low pressure injection after depressurizing.
- At 11:36 on March 12, RCIC automatically shut down.
- At 12:35, HPCI automatically started up.
- Then, Operator headed to the site to switch DD/FP to injection line.
- At 2:42 on March 13, operator manually shut down HPCI and tried to depressurize RPV since reactor pressure got lower than operational limit of HPCI, but...
 - SRV could not be opened due to the loss of batteries.
 - Reactor pressure increased 4MPa, and could not inject water with DD/FP
 - RCIC and HPCI could not be restarted again
 - While water injection stopped, water level decreased and core was exposed
- Around 9:08, rapid depressurization after SRV was forcibly opened.
- At 9:25, fresh water injection was commenced by fire engines.
- At 13:12, seawater injection commenced.

Hydrogen Explosion in Unit 3

- At 11:01 on March 14, explosion occurred in Unit 3 R/B
- Hydrogen was generated due to core damage and leaked from PCV to R/B
- The hydrogen explosion injured 7 employees of TEPCO and its affiliated companies, 4 officers of Self-Defense Force that brought fresh water from off-site
- Seawater injection lines for Units 1, 2 and 3, was damaged by debris
- Circuit to control Unit 2 PCV venting that was temporary restored was also damaged.




Source: TEPCO




AESJ-NSD, Report of the Seminar to Investigate the Accident at the Fukushima-Daiichi Nuclear Power Station, p. 40

On-site Radiation Monitoring in Fukushima Daiichi Site From March 11 to 17, 2011




March 13 11:00
Unit 2's large S/C vent valve (AO valve) was opened and open operation of the valves in the PCV vent line other than the rupture disks was completed.

(D/W pressure did not reach to the operation pressure of 0.427MPa for the rupture disk)



Monitoring Radiation Dose in Fukushima Prefecture



Source: MEXT press release

Evacuation of Residents

➤ The government took measures such as taking shelters or evacuation as follows based on the reports from Fukushima Daiichi & Daini.

Fri, 11 March

14:46 The Earthquake

19:03 Emergency Declaration by the Gov't (Daiichi)

21:23 3 km radius evacuation (Daiichi)

10 km radius taking shelter (Daiichi)

Sat, 12 March

5:44 10 km radius evacuation (Daiichi)

7:45 3 km radius evacuation (Daini)

10 km radius taking shelter (Daini)

17:39 10 km radius evacuation (Daini)

18:25 20 km radius evacuation (Daiichi)

Tue, 15 March

11:00 20-30 km radius taking shelter (Daiichi)


Thu, 21 April

11:00 20 km radius is designated as “**Restricted Area**” (Daiichi)

Fri, 22 April

9:44 20-30 km radius taking shelter has been lifted (Daiichi)

Establishment of “**Planned Evacuation Area**” and “**Emergency Preparation Area**”




Source: NISA website


Evacuation of the Resident (2)

- About 78,000 resident was evacuated from 20 km area almost effectively, but...
 - Some evacuee had to move several time along with the extension of evacuation area.
 - 853 persons in 7 hospitals were evacuated. More than 50 inpatients died in a few month.

Ratio of resident who started evacuating



National Diet of Japan Nuclear Accident Independent Investigation Commission, "Survey of the evacuees from the Fukushima nuclear power plant accident"



Air dose rate observe in Fukushima Daiichi NPS


AESJ-NSD, Report of the Seminar to investigate the Accident at the Fukushima-Daiichi Nuclear Power Station

Cesium Deposition

April 29, 2011


Aerial Measuring Results

Joint US / Japan Survey Data




Monitoring of Radiation Dose Change in 2 Years


November 5, 2011



November 19, 2013



Decrease of Dose Rate through
(1)Radioactive decay
(2)Reduction by natural dispersion
(3)Decontamination action



μ Sv/hr

Overview of Chapter 6 on Accident Analysis and Issues in the AESJ Final Report

The overviews of the following sections in Chapter 6 of the AESJ Final Report;

- ✓ **6.2 Fundamental Concept on Nuclear Safety**
- ✓ **6.3 Defense-in-Depth**
- ✓ **6.4 Accident Management**
- ✓ **6.5 External Events**

Fundamental Concept on Nuclear Safety (1)

- **Objective of Nuclear Safety;**
“Protection of people and the environment from radiation risk arising from facilities and activities”

- **To achieve the objective, it is essential to establish;**
 - **awareness by all parties on the overriding priority of ensuring safety, even though owner or operators of nuclear facilities has prime responsibility for safety;**
 - **shared understanding on, and utilization of quantified risk; and continuous process of discussions on safety goal;**
 - **framework founded on defense-in-depth in managing uncertainties for preventing accidents and controlling risk.**

Fundamental Concept on Nuclear Safety (2)

Fundamental Safety Principles

➤ Principles of Fundamental Nuclear Safety have been clarified by the Standard Committee members of the AESJ

- Responsibility for safety
- Role of the government
- Role of the regulatory body
- Leadership & management for safety

Responsibility & Management

- Fostering safety culture
- Justification of nuclear facilities and activities
- Continuous efforts on controlling radiation consequences on people and the environment

Nuclear Safety Goal

- Prevention and mitigation of accidents
- Emergency preparedness & response
- Protection measures on existing radiation risks, etc.

Controlling of Radiation Risk

➤ Promoting development of a structured codes and standards that begins with Fundamental Safety Principles at the top.

Defense in Depth (1)

Approach and Lessons Learned

- **Lessons learned on Defense in depth**
 - Defense in depth has been introduced into nuclear safety system in Japan with the ultimate goal to prevent severe accidents.
 - In other words, measures so far had relied excessively on protective barriers (Levels 1 to 3) laid out for conditions before a severe accident.
 - However, this was not approach of defense in depth which extends to the realm of level 5 in managing unanticipated events.
 - **Enhancing mitigation of severe accident consequences (level 4) and emergency response(level 5),** including management of extensive radioactivity release, are critical.
 - The defense in depth approach prevails as the effective, founding basis for ensuring nuclear safety, that include the management of external and human events.
 - **All related parties must have deep understanding on defense-in-depth,** and to take actions to ensure safety based on the defense in depth approach.
 - The framework on codes and standards with defense in depth as the underlying safety concept should be formulated and documented.

Defense in Depth (2)

Approach and Lessons Learned

➤ **Defense in depth : Provisions against uncertainties**

- ✓ **Since safety measures are generally laid out on the basis of specific assumptions to the exclusion of other possible scenarios or unexpected events, the effectiveness of a measure contains uncertainties to fully achieve nuclear safety goal on the protection of people and the environment.**
- ✓ **Fundamental approach on defense in depth is the graded approach against the uncertainties by means of successive and independent safety measures to ensure and enhance reliability (independent effectiveness).**
- ✓ **Defense in depth is an effective means for preventing and controlling severe accidents such as the Fukushima Daiichi accident.**

Accident Management

Lessons Learned from the Fukushima Daiichi Accident

- Accident management that was limited to internal events PRA (Probabilistic Risk Assessment)
 - ✓ **Scenarios should be extended to cover external events, internal events and combined events (internal & external).**
- Small probability events had not been included in the AM scope regardless of the magnitude of the source term.
 - ✓ **Consideration of multi-unit sites, large-scale disasters impacting social infrastructure, etc.**
- Absence of measures in case of the loss of critical safety functions
 - ✓ **Consideration of, and measures for extensive dependent failures, such as extended SBO and loss of final heat sink induced by the tsunami.**
- Inadequacies in education and training on accident management
 - ✓ **Need to establish flexible management that includes measures on intangible/human aspects, such as education and training, for complimenting tangible/ hardware aspects.**
- Codes & standards on severe accident management had not been established
 - ✓ **Need to establish codes and standards that satisfy the above requirements**

Accident Management Framework

Accident Management

Management considering tangible/hardware aspects


- ✓ Identification of vulnerabilities based on PRA & stress tests
- ✓ Combined use of permanent & transportable measures
- ✓ Utilization of existing SSCs

Management considering software/human aspects

- ✓ Development of organization & system
- Development of procedure manuals & related software
- ✓ Maintaining/enhancing management competence by training & exercise
- ✓ Operational maintenance management

Other Measures

- ✓ Maintenance management of SSCs classified by management class
- ✓ Management of availability of resources, fuel, etc.
- ✓ Quality management activities, etc.



Knowledge and Management for External Events

History of Measures for Earthquake & Tsunami in Other Plants

Site	Ground Height of Major Buildings	Construction Permit	Chronology of tsunami scenarios after construction permit approval				
			2002 Tsunami Scenario by Japan Society of Civil Engineers	2007 Tsunami scenario for Ibaraki Prefecture	2007 Tsunami scenario for Fukushima Prefecture	2009 Updating submarine topography & tide level conditions	2011 Great East Japan Earthquake observed tsunami heights
Fukushima Dai-ichi	Unit 1-4 O.P. +10m *1 Unit 5 & 6 O.P. +13m	O.P. +3.122m 1966 (Unit 1)	O.P.+5.7m Largest tsunami/w wave source off the coast of Fukushima Implementing measures as elevating seawater intake pumps, etc.	O.P.+4.7m Measures not required	Approx. O.P.+5m Measures not required	O.P.+6.1m Implementing measures as elevating seawater intake pumps, etc.	Tsunami height O.P.+13.1m Inundation height O.P.+15.5m
Fukushima Dai-ni	O.P. +12m	O.P.+3.122m 1972 (Unit 1) O.P.+3.705m 1978 (Unit 3,4)	O.P.+5.2m Implementation of watertightness measures for buildings	O.P.+4.7m Measures not required	O.P.+5m Measures not required	O.P.+5.0m Measures not required	Tsunami height O.P.+7~8m Inundation height O.P.+14.5m
Onagawa	O.P. +14.8m	O.P.+2~3m: 1970 (Unit 1; per document search) O.P.+9.1m 1987 (Unit 2, numerical calculation)	O.P.+13.6m Largest tsunami/w wave source off the coast of Sanriku Measures not required	— —	— —	— —	Tsunami height O.P.+13.8m
Tokai Dai-ni	H.P. +8.9m Installation height of seawater intake pump +4.2m	H.P.+2.35m 1971	H.P.+5.75m Measures not required	H.P.+6.61m Implementing measures as elevating seawater intake pumps, etc. (H.P.:+7m)	— —	— —	Tsunami height H.P.+5.5m Inundation height H.P.+6.2m

Direct Causes of the Fukushima Daiichi Accident

Final Report of the AESJ Investigation Committee

➤ **Inadequacies in Tsunami Measures**

- Critical incidents and related knowledge have not been utilized for developing effective prevention measures. Ex. Jogan Off the Coast Sanriku Tsunami Earthquake

➤ **Inadequacies in Severe Accident Management Measures**

- No reinforcement of severe accident management measures after 2002.
- No severe accident management measures for external events as earthquakes and tsunamis.
- Japan did not adopt reinforcement of terrorist measures taken by many countries after 9.11.

➤ **Inadequacies in Emergency Responses, Post-accident Management and Other Mitigation/Recovery Measures**

- The setting of a 10-kilometer radius emergency evacuation zone was not sufficient.
- Emergency offsite center was damaged by the earthquake and could not be used.
- Municipal/government directions on Iodine intake was not communicated sufficiently, resulting in the intake by only a few of the local population.

Underlying Causes of the Accident

Final Report of the AESJ Investigation Committee

- 1. Lack of awareness on the roles & responsibilities by experts**
- 2. Shortfalls in establishing safety measures & fostering safety awareness by utilities**
- 3. Lack of safety awareness by the regulatory body**
- 4. Inadequacies in attitude of learning from efforts and collaborative works in the international community**
- 5. Shortage of qualified personnel dedicated to ensuring safety and inadequacies in organization & management framework**

Recommendations made by Final Report of the AESJ Investigation Committee

50 Items in 5 Categories

- 1. Items Related to Direct Causes (5)**
- 2. Items Related to Organizational Factors of the Underlying Causes (14)**
- 3. Items Related to Nuclear Safety Fundamentals (14)**
- 4. Common Items (12)**
- 5. Items Related to Post-Accident Management (5)**

Recommendation I

- Nuclear Safety Fundamentals -

- 1. Clarification of nuclear safety objectives**
 - ① Establishing consensus on nuclear safety goal
 - ② Systematic requirements by regulatory standards
 - ③ Enhancement of nuclear security

- 2. Deepening understanding and reinforcement of defense-in-depth**
 - ① Clarification of Fundamental Safety Principles
 - ② Stipulation/documentation of defense-in-depth

Recommendation II

- Items Related to Direct Cause -

1. Enhancing Measures for External Events

- ① Individual plant examination for external events
- ② Measures for cliff edge effects
- ③ Measures for intentional attacks

2. Reinforcing Severe Accident Management Measures

3. Enhancing Framework for Emergency Preparedness and Response

- ① Establishment of collaboration between utilities and local governments
- ② Clarification of the roles of related parties
- ③ Conducting drills and exercises
- ④ Radioactive material dispersion analysis
- ⑤ Establishing integrated management framework with other natural disaster
- ⑥ Enhancing competence in managing radiation protection

4. Enhancing Nuclear Safety Assessment Technique

- ① Utilization of Probabilistic Risk Assessment
- ② Utilization of simulation based on leading edge computing technologies
- ③ Better understanding on issues & limitations on safety assessment technique
- ④ Promotion of international collaboration

Recommendation III

- Organizational Factors of Underlying Causes -

1. Efforts by Professional Societies and the Academia

- ① Re-acknowledging responsibilities of academic societies
- ② Fostering open and inclusive atmosphere for discussions at academic societies
- ③ Enhancing safety research
- ④ Promoting inter-disciplinary collaboration
- ⑤ Contributing to continuous improvements of safety regulations

2. Efforts by Nuclear Industries

- ① Sharing lessons learned on the accident by nuclear industrial community
- ② Implementation of continuous improvements for nuclear safety
- ③ Top management commitment to nuclear safety

3. Efforts by Nuclear Safety Regulatory Body

- ① Restoring public confidence
- ② Continuous improvements
- ③ Introduction of risk-informed regulations
- ④ Transition from regulations emphasizing tangible aspects to regulations focusing on intangible aspects
- ⑤ Guiding utilities to establish voluntary safety enhancement efforts
- ⑥ Well-balanced approach in utilizing professional expertise in broad areas

Recommendation IV - Common Items -

1. Enhancing nuclear safety research platform

- ① Keep the driving force in safety enhancement
- ② Importance of maintaining & developing qualified personnel resources
- ③ Responsibility of government organizations, industries, and the academia for safety research
- ④ Extensive application of PRA technique
- ⑤ Development of roadmap for wide range of safety research

2. Enhancing international collaboration

- ① Developing system to reflecting the outcomes of international activities on domestic system
- ② Contributing to activities of countries newly introducing nuclear power
- ③ Participation by the industrial community in international activities

3. Development of nuclear personnel resources

- ① Values on the overriding priority of nuclear safety
- ② Enhancement of personnel qualification system
- ③ Importance of university level education & research on nuclear energy
- ④ Education on nuclear energy & radiation in junior/senior high school

Recommendation V

- Items Related to Post-Accident Management -

Environment Remediation and Decommissioning Activities

- ① Environment monitoring
- ② Regulations and guidelines
- ③ Designation of areas to be decontaminated
- ④ Decontamination and decontamination technique
- ⑤ Management & storage of decontaminated wastes

Summary of the Recommendations

Final Report of the AESJ Investigation Committee

- **Recommendations have been made over broad areas based on the results of root cause analysis.**
- **A broad range of issues need to be addressed for ensuring nuclear safety:**
 - fundamental concept on nuclear safety must be clearly shown
 - PRA appropriately applied
 - safety goal defined clearly
 - defense-in-depth accurately understood and applied to plant design, accident management, disaster management, etc.
- **The importance on the role of nuclear safety research for resolving these issues and its continuous development is emphasized.** Research activities will lead to expand knowledge-base; to get deeper insight on the broader issues and to generate better and optimized solutions out of possible options.

Epilogue

- **The recommendations have been made to prompt government organizations, the industries, the academia and research institutions to take concrete actions for promoting nuclear safety.**
- Some of the recommendations involve goals to be pursued by the AESJ. Concurrently with making efforts on necessary improvements, the AESJ aims to interact with related organizations for the realization of the recommendations.
- These recommendations have been proposed, in view of the significance of transparency of nuclear-related information, to be shared by all parties with interest in nuclear power. It is critically important for all organizations and experts to take to heart the items recommended and to endeavor earnestly for the achievement of nuclear safety.
- **Unless these goals are realized, organizations and experts in nuclear power field are not qualified to be involved in nuclear activities. (Prof. Satoru Tanaka, Chairman of the Committee)**

**English version of Final Report of the AESJ Investigation Committee,
available from Springer**

 Springer

ISBN 978-4-431-55159-1

springer.com

Editor :
Atomic Energy Society of Japan



The Fukushima Daiichi Nuclear Accident

Final Report of AESJ Investigation Committee

560 pages

This report was completed by the AESJ, Japanese
academia in nuclear science/engineering, with
concerted effort by specialists.

It covers all aspects of technical issues of the Accident.

New
Book

Thank you very much for your attention



Summary of the Accidents in Fukushima Daiichi and Fukushima Daini

Date	Fukushima Daiichi (1F)						Fukushima Daini (2F)			
	Unit 1	2	3	4	5	6	Unit 1	2	3	4
3/11	3/11 15:27 1 st Tsunami, 15:35 2 nd Tsunami						3/11 15:22~ Tsunamis			
	Station Black-Out									
3/12	3/12 8:13 D/G-6B									
	3/12 15:36 Unit 1 Explosion						3/12 12:15			
3/13	Loss of Ultimate Heat Sink									
							3/14 1:24 RHR			
3/14							3/14 7:13 RHR			
	3/14 11:01 Unit 3 Explosion						3/14 15:42 RHR			
3/15	3/15 6:00-6:10 Unit 4 Explosion						3/14 17:00			
							3/14 18:00			
3/16-19							3/19 5:00 RHR			
							3/19 22:14 RHR			
3/20	3/20 15:46 P/C-2C						3/20 14:30			
	3/20 15:46 P/C-2C						3/20 14:30			
3/22	3/22 10:36 P/C-4D						Cold Shutdown			
	3/22 10:35 P/C-4D									

Maximum Acceleration Observed in Fukushima Daiichi

Location of Seismometer (bottom floors of the reactor buildings)		Records			Max. Response Acceleration to the Design Basis Ground Motion, S _s (Gal)		
		Max. Acceleration (Gal)			NS	EW	UD
		NS	EW	UD			
Fukushima Daiichi	Unit 1	460※ ¹	447※ ¹	258※ ¹	487	489	412
	Unit 2	348※ ¹	550※ ¹	302※ ¹	441	438	420
	Unit 3	322※ ¹	507※ ¹	231※ ¹	449	441	429
	Unit 4	281※ ¹	319※ ¹	200※ ¹	447	445	422
	Unit 5	311※ ¹	548※ ¹	256※ ¹	452	452	427
	Unit 6	298※ ¹	444※ ¹	244	445	448	415

※¹: Each recording was interrupted at around 130-150(s) from recording start time

※²: 1 Gal=0.01m/s² , 981 Gal=1G

Source: Added to “The impact of the 2011 off the Pacific coast of Tohoku Earthquake to Nuclear Reactor Facilities at Fukushima Dai-ichi Nuclear Power Station” (Sep. 9, 2011, revised Sept. 28, 2011, TEPCO)

Tsunami in Fukushima Daiichi on March 11, 2011

15:36:10



15:36:16



15:36:56



15:37:06



15:37:24



15:37:48



15:38:14



15:38:28



15:39:40



15.5 m above
the sea level




Source: TEPCO

Inundation height of the Tsunami in Fukushima Daiichi was about 15.5 m above the sea level.

(Correction of Time based on TEPCO)


Data from Instrumentations Systems on March 11 in Units 1 & 2



- Since DC power was lost, plant parameters in Unit 1 and Unit 2 could not be observed
- Operators in Unit 1 & 2 could not confirm **whether water injection was active** or not
- At 20:07, Unit 1 reactor pressure was confirmed to be 6.9 kPa, by checking pressure gage in the R/B.
- At 20:47, The ERC Recovery Team brought small generator and restored lighting in Unit 1&2 MCR.
- At 21:19, Unit 1 reactor water level indicator was restored, showing +200 mm, but the value was found to be incorrect later (explained afterwards)
- At 21:51, Radiation dose rose in Unit 1 R/B
- At 21:50, Unit 2 reactor water level was determined as TAF +3,400 mm
- At 23:25, Unit 2 D/W pressure was confirmed to be 141 kPa
- At 23:50, Unit 1 D/W pressure was confirmed to be 600 kPa
- Plant parameters showed
 - Unit 1 was under severe condition
 - Unit 2 was stable

Protecting Containment Vessel in Unit 1

- In the morning of March 12, Unit 1 PCV pressure stabilized round 750 kPa.
- At 9:04, operators headed to the field for venting operation
- At 9:15, first team opened PCV vent valve (MO valve)
- Second team could not reach to the S/C vent bypass valve due to high dose rate
- From 10:17, remote operation of the valve was performed
- At 14:30, release of radioactive material by venting was determined
 ⇒ Rapture of PCV was prevented, but leakage occurred due to the overheating



TEPCO, Fukushima Nuclear Accidents Investigation Report, Attachment 8-6,


Hydrogen Explosion in Unit 1

- At 21:51 on March 11, radiation dose rose in Unit 1 R/B.
- In the morning of March 12, Unit 1 PCV pressure stabilized round 750 kPa.
- At 15:36 on March 12, explosion occurred at 4th & 5th floor in Unit 1 R/B
- Hydrogen was generated due to core damage and leaked from PCV to R/B
- The hydrogen explosion injured 5 people, destroyed an high voltage power generating truck that had just been connected with the survived power distribution board in Unit 2, and sprayed debris that is highly radioactive.

All walls were damaged



Source: TEPCO




Ceiling was crashed


All walls were damaged

AESJ-NSD, Report of the Seminar to investigate the Accident at the Fukushima-Daiichi Nuclear Power Station, p. 31




*) The analysis results after the RPV rupture do not mean water levels are kept constant





Unit 1




Unit 1




Unit 1




Release Rates of Fission Products in Various Chemical Forms in Unit 1




Unit 1



Release Rates of Fission Products in Various Chemical Forms in Unit 2 (MAAP code)




Unit 2





Investigation Result of the Inside of PCV of Unit 2

By investigations using an endoscope system, it was confirmed that:

- Water level in PCV is approx. 60 cm,
- Water temperature is approx. 50°C,
- and
- Dose rate of gas phase is 73 Sv/h.



<Industrial endoscope of 20m>



(Source: TEPCO)

Damage of Field on Site caused by the Earthquake and Tsunami




Falling rock prevention fence
One side of the road on the westside was cracked and subsided in parallel with road. West side was accessible. Photo taken 3/17



Reinforcement work was conducted on this road, but cracks and subsidence was found on both sides of the road which were not reinforced. Photo taken 3/17



Though not a priority emergency route, the slope failed and the road was blocked and impassable. Photo taken 3/20



Heavy oil tank
No major damage to the road, but the heavy oil tank carried by the tsunami blocked the road making it impassable. Photo taken 3/17



No particular abnormality found with straight road from main gate. Photo taken 8/26



No particular abnormality with the road but scattered rubble. Photo taken 3/16



No particular abnormality with Units 1 to 4 west side road. Rubble was scattered when Units 1, 3, 4 R/B were damaged. Photo taken 3/20




Some rubble scattered but no particular damage to roads. Photo taken 3/20

- Emergency priority route
- Non-emergency priority route major routes
- Impassable
- Photo location & direction

Failure of Water Injection Using Isolation Condenser System in Unit 1

Though Unit 1 IC was a passive injection system, it lost the function due to the loss of both AC and DC power supply.



When tsunami attacked,

- Operator was using IC-A to control reactor pressure
- DC power for system A was lost
- Rupture detection circuit for IC-A was lost
- Valve 1A and 4A inside PCV were closed using AC power due to fail safe mechanism. IC-A lost its function
- AC power was lost. Restoration got difficult.


Water Level Measurement in Unit 1

At 21:19 on March 1, Unit 1 reactor water level gage was powered. It showed TAF +200 mm, but . . .

In fact, fuel had been exposed at that time.


Water gauges measure the difference of pressure between the Reference leg and the water phase of the reactor

Water gauges required calibration when the reference leg was dried-off or water level decreased significantly



RCIC in Unit 2 Sustained the Function after Loss of DC Power


Though Unit 2 RCIC was not a passive injection system, it had partly sustained the function after the loss of power supply until March 14




- When power for RCIC was lost, the valves for RCIC operation was open
- RCIC did not stop the operation due to the loss of the automatic control
- RCIC turbine was driven by two-phase flow when water level was higher than the limit

Air Dose Rate in Fukushima Daiichi NPS


- The closest monitoring posts were not available due to the earthquake, tsunami, and blackout.
- Migration of radioactive plume was strongly affected by daily circulation of the wind.
 - Towards South (early morning) → Towards West (morning) → Towards North-West (afternoon) → Towards East (night)
- Radionuclides were contaminated on North-West region of the NPS after the rain in the midnight of March 15.



Plant Parameters in Unit 1



Plant Parameters in Unit 3



Cooling Unit 2 Reactor Core

- While Unit 2 RCIC was functioned,
 - SRV control panel was powered by potable batteries on March 13 to depressurize after RCIC stop
 - Seawater injection line was prepared using fire engine
 - PCV vent line was completed except the break of rupture disk
- But these measures were damaged by hydrogen explosion in Unit 3.
- At 13:25 on March 14, loss of RCIC was confirmed.
- Since S/C temperature exceeded 100 °C and the steam would not condense easily, decision was made to depressurized after venting was lined up.




Source: TEPCO


- At 14:43, connection of fire engine was restored, but restoration of venting took time.
- At 16:21, the president of TEPCO ordered to depressurize at first, but SRV did not worked well until 18:02.
- At 19:20, shutdown of fire engine due to the lack of fuel was confirmed.
- At 19:57, two fire engines started up, and sea water injection was commenced.

Plant Parameters in Unit 2

- According to the severe accident simulation, fuel started exposing around 9:10, and core damage started 10:40 on March 13.




Stand-by Gas Treatment Systems for Units 3 and 4




Pipes of stand-by gas treatment systems for Units 3 and 4 are connected.

Source: TEPCO



Possible Mechanism of Hydrogen Explosion in Unit 4



Amount of Released Radioactive Material to determine INES Rating (April 11, 2011)

	Estimated release from Fukushima Daiichi		Release from Chernobyl
	by NISA	by Nuclear Safety Commission	
I-131 (a)	$1.3 \times 10^{17} \text{Bq}$	$1.5 \times 10^{17} \text{Bq}$	$1.8 \times 10^{18} \text{Bq}$
Cs-137	$6.0 \times 10^{15} \text{Bq}$	$1.2 \times 10^{16} \text{Bq}$	$8.5 \times 10^{16} \text{Bq}$
Iodine value conversion (b)	$2.4 \times 10^{17} \text{Bq}$	$4.8 \times 10^{17} \text{Bq}$	$3.4 \times 10^{18} \text{Bq}$
(a) + (b)	$3.7 \times 10^{17} \text{Bq}$	$6.3 \times 10^{17} \text{Bq}$	$5.2 \times 10^{18} \text{Bq}$

INES level 7 > 10^{16}Bq Iodine equivalent

INES : International Nuclear Event Scale

INES Manual (2008) co-sponsored by IAEA and OECD/NEA

International Nuclear Event Scale (INES)

Off-site Impact

On-site Impact

Defense-in-Depth Degradation

7

Major release

6

Significant release

5

Limited release

4

Minor release

3

Very small release

2

Severe damage

Significant damage
/ Fatal exposure of worker

Severe spread
of contamination
/ health effects to worker

Significant spread
of contamination
/ overexposure of worker

Near accident

Significant failure

**Beyond
Operation limit**

1

0


Out of scale

Overview of Events in Unit 1


- **14:46 on March 11, 2011 : Earthquake**
 - Reactor scram**
 - Loss of offsite power, AC power with DG**
 - Hot standby with Isolation condenser (IC)**
- **15:30 on March 11 : Tsunami arrival**
 - Loss of all AC & DC power**
 - => Loss of ECCS & IC**
 - => Loss of reactor cooling**
- **Shortly before 7:00 pm Mar. 11th**
 - Core damage**
- **Approx. 4:00 am Mar. 12th**
 - Reactor core coolant injection via fire engine begins**
- **3:36 pm Mar. 12th**
 - Hydrogen explosion in reactor building**

Estimated Core Damage in Unit 1

- Simulation Results of Fuel Damage by the MAAP code -





About 3.9 hours after SCRAM




About 5.0 hours after SCRAM

Degree of fuel damage




About 11.5 hours after SCRAM



About 12.0 hours after SCRAM

- Melting starts from the central part of the core.
- In 12 hours after scram, most part of the core fell down to the RPV bottom.

Summary of Core Damage in Unit 1



- Severe Accident code analysis indicates;


All fuel rods were melted and relocated to the RPV bottom. Considerable amount of fuel dropped to the PCV bottom.

- **Almost all fuel dropped to the PCV bottom, is in contact with water, and is cooled.**
- Currently water is injected to the RPV via the feed water piping and core spray piping. Temperature of the RPV bottom and the PCV is stable well below 100 C.

Location of Gas Leak from RPV to PCV in Unit 1

- Possible paths of gaseous leakage from the reactor vessel to the D/W are the in-core instrumentation dry tube or the main steam line flange gasket.
- The in-core instrumentation dry tube can be damaged when fuel temperatures are elevated.
- The main steam line flange gasket may lose its airtightness at temperature of about 450 C.

SRM : Source Range Monitor
IRM : Intermediate Range Monitor
TIP : Travelling In-core Probe



Overview of the Events in Unit 2

- 2:46pm Mar. 11th Earthquake occurrence: Offsite power failure
Plant scrammed to shutdown
RCIC and SR valves => transit to hot standby
- 3:30pm Mar. 11th tsunami arrival:
Loss of all AC and DC power sources => loss of ECCS
RCIC was manually activated before power failure, and it ran uncontrolled
- Noon Mar. 14th: loss of RCIC
- 7:20pm Mar. 14th: reactor core damage
- 7:57pm Mar. 14th: reactor core injection begins via fire engine
- No hydrogen explosion in reactor building (because reactor blowdown panel was released open by the explosion in Unit 1)




Fig. 3.7 Reactor water level (Unit 2)

Overview of the Events in Unit 3

- 2:46pm Mar. 11th Earthquake occurrence: Offsite power failure
Plant scrambled to shutdown
RCIC and SR valves => transit to hot standby
- 3:30 pm Mar. 11th Tsunami arrival
Loss of all AC power source => Low-pressure ECCS failure
DC power maintained => Reactor cooling via RCIC, HPCI
- 2:42 pm Mar. 13th
HPCI suspended (DC power loss) => Failure in switching to D/DFP
- 9:25am Mar. 13th
After de-pressurization via SR valve,
coolant injection into reactor core via
fire engine begins
- 10:40am Mar. 13th
Core damage
- 11:01am Mar. 14th
Hydrogen explosion of reactor build






Fig. 3.11 Reactor water level (Unit 3)

Fundamental Safety Functions for Light Water Reactors


Shutting Down by interrupting fission chain reaction through insertion of control rods

Cooling Down the fuels through continuous water injection and circulation

Confining radioactive materials inside the boundary (RPV and PCV)


- 
- 1. High-pressure Coolant Injection**
 - 2. Depressurization**
 - 3. Low-pressure Coolant Injection**
 - 4. Heat Removal to Ultimate Heat Sink (Ocean)**
- 

Schematic System Diagram in Unit 2 after the Tsunami



RCIC continued to operate until 13:25 on March 14.



Schematic System Diagram in Unit 3 after the Tsunami



After RCIC stopped at 11:36AM on March 12, HPCI started up automatically. Batteries ran out, and HPCI stopped by 2:42AM on March 13.


High-pressure Coolant Injection

Water is put into the high-pressure reactor pressure vessel to cool the reactor core and maintain water levels.




Depressurization

Lower the pressure of the pressure vessel to enable low-pressure coolant injection and heat removal.




Most of the steam flows to the suppression pool, and pressure in the pressure vessel goes down




Hydrogen Explosion in Unit 4

- At 6:12 on March 15, with loud noise and vibration, Unit 4 R/B was damaged.
- Later investigation showed that hydrogen generated in Unit 3 flew into Unit 4
 - There is a possible path from PCV vent line shared by Unit 3&4 through Unit 4 SGTS line into Unit 4 R/B
 - Fuels in spent fuel pool (SFP) are not damaged.





Source: TEPCO



AESJ-NSD, Report of the Seminar to investigate the Accident at the Fukushima-Daiichi Nuclear Power Station, p. 41

TEPCO, Fukushima Nuclear Accidents Investigation Report, p. 345

- At the same time of the explosion, S/C pressure in Unit 2 dropped to be zero.
- People thought that the explosion occurred in Unit 2.
- But the assumption was denied by the seismic records.



TEPCO, Fukushima Nuclear Accidents Investigation Report, p. 339

Unit 3




Hydrogen Explosion on 11 AM, March 14



Source: TEPCO

Unit 2



Unit 4


Explosion at on 6 AM, March 15



Unit 3

Unit 4


Summary of Core Damage in Unit 2



By investigations using an endoscope system, it was confirmed that:





- Water level in PCV is approx. 60 cm,
- Water temperature is approx. 50°C, and
- Dose rate of gas phase is 73 Sv/h.

<Industrial endoscope of 20m>









Estimated Core Damage in Unit 2


- Simulation Results by the MAAP code -



Degree of Fuel Damage

-  Normal fuel
-  Collapsed fuels piled up
(Fuel rod shapes were kept)
-  Fuel rod diameters increased due to molten fuel flowing down on their surfaces and solidifying there
-  Fuel rod diameters further increased and blocked the downward flowing path
-  Molten core pool formed
-  Void (fuel melted down)





Summary of Core Damage in Unit 3









- It was possible to control the RCIC and HPCI and continue cooling, as batteries can be used.
- After RCIC stopped at 11:36 on March 12, HPCI started up automatically.
- At 20:00 on March 12, reactor pressure fell below HPCI design condition 1MPag to about 0.8 MPag. (No cooling water was injected into the reactor after that time.)
- Batteries ran out, and HPCI stopped by 2:42 on March 13.
- A hydrogen explosion occurred in the reactor building at 11:01 on March 14.

Estimated Core Damage in Unit 3

- Simulation Results by the MAAP code -



Degree of Fuel Damage

-  Normal fuel
-  Collapsed fuels piled up (Fuel rod shapes were kept)
-  Fuel rod diameters increased due to molten fuel flowing down on their surfaces and solidifying there
-  Fuel rod diameters further increased and blocked the downward flowing path
-  Molten core pool formed
-  Void (fuel melted down)

Radionuclides considered Important in the Reactor Safety Study Consequence Analysis (1)

3,200 MWth PWR case

Radionuclides	Half-life [days]	Shutdown inventory [MCi]
1) Noble gases		
⁸⁵ Kr*	3950	0.56
^{85m} Kr*	0.183	24
⁸⁷ Kr*	0.0528	47
⁸⁸ Kr*	0.117	68
¹³³ Xe	5.28	170
¹³⁵ Xe	0.384	34
2) Halogens		
¹³¹ I	8.05	85
¹³² I	0.0958	120
¹³³ I	0.875	170
¹³⁴ I	0.0366	190
¹³⁵ I	0.28	150
3) Alkali metals		
¹³⁴ Cs	750	7.5
¹³⁶ Cs	13	3
¹³⁷ Cs	11000	4.7
⁸⁶ Rb*	18.7	0.026

4) Tellurium group		
¹²⁷ Te*	0.391	5.9
^{127m} Te	109	1.1
¹²⁹ Te*	0.048	31
^{129m} Te	0.34	5.3
^{131m} Te	1.25	13
¹³² Te	3.25	120
¹²⁷ Sb	3.88	6.1
¹²⁹ Sb	0.179	33
5) Barium and strontium group		
⁸⁹ Sr	52.1	94
⁹⁰ Sr	11030	3.7
⁹¹ Sr	0.403	110
¹⁴⁰ Ba	12.8	160

*** Indicates negligible contribution to health effects**

Radionuclides considered Important in the Reactor Safety Study Consequence Analysis (2)

Radionuclides	Half-life [days]	Shutdown inventory [MCi]
6) Noble metals		
⁵⁸ Co*	71	0.78
⁶⁰ Co*	1920	0.29
⁹⁹ Mo	2.8	160
^{99m} Tc*	0.25	140
¹⁰³ Ru	39.5	110
¹⁰⁵ Ru*	0.185	72
¹⁰⁶ Ru	366	25
¹⁰⁵ Rh*	1.5	49

7+8) Lanthanides and cerium group		
⁹⁰ Y*	2.67	3.9
⁹¹ Y	59	120
⁹⁵ Zr	65.2	150
⁹⁷ Zr	0.71	150
⁹⁵ Nb	35	150
¹⁴⁰ La	1.67	160
¹⁴¹ Ce	32.3	150
¹⁴³ Ce*	1.38	130
¹⁴⁴ Ce	284	85
¹⁴³ Pr	13.7	130
¹⁴⁷ Nd*	11.1	60
²³⁹ Np	2.35	1640
²³⁸ Pu	32500	0.057
²³⁹ Pu	8.90E+06	0.021
²⁴⁰ Pu	2.40E+06	0.021
²⁴¹ Pu	5350	3.4
²⁴¹ Am*	1.50E+05	0.0017
²⁴² Cm	163	0.5
²⁴⁴ Cm	6630	0.023

3,200 MWth PWR case

*** Indicates negligible contribution to health effects**

Additional Slides

New Safety Standards in Japan

< New Safety Standards >

< Previous Safety Standards >

Design Basis Standard
to prevent Severe Core Damage
(Only assuming single failure etc.)

Consideration for Natural Events
Consideration for Fire
Consideration for Reliability
Reliability of power source
Performance of cooling equipment
Performance of other equipment
Tolerability for Earthquake & Tsunami

Preventing Large Scale Release
Intentional Airplane Crash
Preventing CV Failure
Preventing Severe Core Damage (Assuming multiple malfunction)
Consideration for Natural Events
Consideration for Fire
Consideration for Reliability
Reliability of power source
Performance of cooling equipment
Performance of other equipment
Tolerability for Earthquake & Tsunami

New
(Countermeasures
against
Severe Accident)

Enhancement

Enhancement

Enhancement of Design Basis Standard

Review Design Basis Standard completely,

“Design Basis Standard with No Severe Core Damage assumed”

- ① Tornadoes and Bushfires included as Natural Events to be considered**
- ② Enhancement of Fire Protection**
- ③ Enhance Reliability of Components particularly important to the safety
(Redundancy of Components with Long Time Demand)**
- ④ Enhancing external electricity supplies
(Multiple Power Line Systems from Separate Substations)**
- ⑤ Physical Protection of Heat Removal System
(Protection of Seawater Pumps)**

Countermeasures against SA (Severe Core Damage)

Requirements for Countermeasures against Severe Core Damage assuming beyond the Design Basis Accidents.

- ① Countermeasures for Failure of Reactor Shutdown**
- ② Countermeasures for Loss of Cooling Reactor (at high pressure)**
- ③ Countermeasures for Loss of Depressurization**
- ④ Countermeasures for Loss of Cooling Reactor (at low pressure)**
- ⑤ Countermeasures for Loss of Ultimate Heat Sink (LUHS)**
- ⑥ Securing Support Function (Make-up Water, Electricity Sources)**

Countermeasures against SA (Containment Vessel Failure)

Requirements for Countermeasures against Containment Vessel Failure assuming Severe Core Damage.

- ① Countermeasures for Cooling, Depressurization and Radioactive Material Mitigation (CV Spray)**
- ② Countermeasures for Cooling and Depressurization of CV (Filtered Venting system)**
- ③ Countermeasures for Cooling Melted Core fallen to the Bottom of CV**
- ④ Countermeasures against Hydrogen Explosions inside CV**
- ⑤ Countermeasures against Hydrogen Explosions at the Reactor Building, etc.**
- ⑥ Countermeasures for Cooling of Spent Fuel Storage Pools**


Countermeasures against Extreme External Hazards

- **Flexible measures mainly by mobile facilities**
 - Against loss of large area of plant by various accidents, hazards, and attacks
 - To maintain/restore cooling function in PCV, CV, and SFP
 - Facilities stored safely against extreme external hazards
 - Electricity and water inlets available under loss of large area of plant
- **Hardened fixed facilities**
 - Against postulated external events beyond design basis with relatively high frequency
 - To improve reliability of countermeasures
 - To prevent large release of radioactive substances
 - Hardened facilities, e.g. water injection to CV spray and pedestal, filtered vent

Regulatory Requirements for Power Supply


- Fuel for emergency diesel generators should be stored in the for 7 days of continuous operation (to prepare possible loss of external power supply)
- Independent power supply as severe accident measure (in case of possible station black out)
- No core damage before the connection to independent power supply (as plant design criteria)
- DC power supply capability for 24 hours (as severe accident management criteria)
- Additional sets of DC power supply before 2020

30 Measures that Should Be Addressed to Regulation Identified in NISA Report in February 2012



Basic Policies for the New Regulatory Requirements


- Establish requirements to prevent loss of safety functions due to common causes and progression of severe accidents



Flow chart for Defense-in-Depth

(IAEA INSAG definition)

- Success is defined for each level of defense -in-depth.
- If the provisions of a given level of defense fail to control the evolution of a sequence, the subsequent level will come into play.



Summary of Insights from Beyond Design Basis Considerations

Inadequate Consideration of Beyond Design Basis Accidents (BDDBA)

**Inadequate Assurance of Core
Cooling Capability for BDDBA
Scenarios in the Design**

**Inadequate Consideration of
BDDBA in Accident
Management**

**Failure to
ensure core
cooling in
BDDBA
conditions**

**Failure of
plant
indication in
MCRs and
ERCs**

**BDDBA
documented
guidance
inadequate**

**Insufficient
classroom
training,
drills and
exercises**

MCR : Main Control Room

ERC : Emergency Response Center




Visit to Fukushima Daiichi Site on April 9, 2012

Unit 4



Low Pressure Coolant Injection

- Introduce water to cool the reactor core and maintain water levels






Flow of water

Flow of water

Heat Removal


- Transfer the heat coming from the reactor core to water to release it outside



Primary Containment Vessel Venting Operation


No power source for the MO-valve
 No power source to the solenoid valve
 Low pressure to actuate the AO-valve
 High radiation level in R/B

- ➔ Manual operation
- ➔ Engine driven generator
- ➔ Engine driven air compressor



Self-contained breathing apparatus

On-site Radiation Monitoring in Fukushima Daiichi Site From March 11 to 18, 2011




Fuel Assemblies in Reactor Core and Spent Fuel Pool

<i>Unit</i>	<i>1</i>	<i>2</i>	<i>3</i>	<i>4</i>	<i>5</i>	<i>6</i>
<i>Number of Fuel Assembly in the Core</i>	400	548	548*	-	548	764
<i>Number of <u>Spent</u> Fuel Assembly in the SFP</i>	292	587	514	1,331	946	876
<i>Number of <u>New</u> Fuel Assembly in the SFP</i>	100	28	52	204	48	64
<i>Water Volume (m³)</i>	1,020	1,425	1,425	1,425	1,425	1,497
<i>Heat Generation in Spent Fuel Pool (MW)</i>	0.18	0.62	0.54	2.26	0.08	0.07

** including 32 MOX Fuel Assembly*

Hydrogen Explosion in Unit 4 on March 15

Possible mechanisms ; (1) Zr-H₂O reaction in the SFP, (2) H₂ from Unit 3,
(3) Decomposition of H₂O into H₂ and O₂ under radiation



Unit 4 : Spent Fuel Pool

- ◆ *No significant damage was identified by underwater camera inspection*
- ◆ *Water sampling also shows relatively low radioactivity in SFP water*

*Analysis result of water in the SFP of Unit 4
(Date of Collection April 12 and 28)*

<i>Detected Nuclides</i>	<i>Density (Bq/cm³) on April 12</i>	<i>Density (Bq/cm³) on April 28</i>
<i>Cesium 134</i>	<i>88</i>	<i>-</i>
<i>Cesium 137</i>	<i>93</i>	<i>55</i>
<i>Iodine 131</i>	<i>220</i>	<i>27</i>

Source: TEPCO



Source: TEPCO

~~(A)~~ **Zr-H₂O reaction in the SFP at high temperature**


Experiments on High Concentration of Hydrogen Gas under Radiation at Boiling Temperature

G-values	-H ₂ O	e ⁻ _{aq}	OH	H	H ₂ O ₂	H ₂	HO ₂
Gamma-ray	4.1	2.7	2.8	0.56	0.68	0.45	~0.01
Alpha-ray	2.65	0.06	0.24	0.21	0.985	1.3	0.22

May 16, 2011

Prof. Katsumura Group

The University of Tokyo and JAEA




Typical BWR condition simulation of radiation chemistry reactions considering the reaction between H₂ and OH, resulting in steady state concentration of H₂.

New Finding by H₂ production under irradiation;


- Effective transfer of H₂ into gas phase at 100 C
- High concentration of H₂ through condensation of H₂O at lower temperature region

6.8 kGy/h for 1 hr
at 80, 97 and 100 C



Experimental Set-up at JAEA Takasaki


30 Measures that Should Be Addressed to Regulation Identified in NISA Report in February 2012



Lessons Learned Identified in Report to IAEA Ministerial Conference in June 2011

<p><i>Enhancement of Preventive Measures against Severe Accidents</i></p>	<p>(1) Strengthening of measures against earthquake and tsunami (2) Ensuring power supplies (3) Ensuring robust cooling functions of reactors and PCVs (4) Ensuring robust cooling functions of spent fuel pools (5) Thorough accident management (AM) measures (6) Resolution of issues concerning multi unit site (7) Consideration of NPS layout in basic designs (8) Ensuring water tightness of essential equipment / facilities</p> <p style="text-align: right;">Source: Report of Japanese Government to the IAEA Ministerial Conference on Nuclear Safety http://www.kantei.go.jp/foreign/kan/topics/201106/iae_a_houkokusho_e.html</p>
<p><i>Enhancement of Mitigation Measures of Severe Accidents</i></p>	<p>(9) Enhancement of measures to prevent hydrogen explosion (10) Enhancement of containment venting system (11) Improvement of environment / habitability for emergency response (12) Enhancement of radiation protection management system in case of accident (13) Enhancement of training responding to severe accidents (14) Enhancement of instrumentation for reactors, PCVs, etc. (15) Implementation of centralized control of equipment for emergency and rescue team</p>
<p><i>Enhancement of Nuclear Emergency Responses</i></p>	<p>(16) Response to combined emergencies of natural disasters and prolonged nuclear accident (17) Enhancement of environmental monitoring (18) Clarification of roles and responsibilities of central and local organizations (19) Enhancement of communication in case of accident (20) Enhancement of response to assistance from overseas and information supply to international community (21) Adequate understanding and prediction of consequences of radioactive releases (22) Clarification of standards for evacuation in wide areas and radiation protection in case of emergency</p>
<p><i>Reinforcement of Safety Infrastructure</i></p>	<p>(23) Enhancement of framework for safety regulation (24) Enhancement / implementation of legal framework and regulatory guides and standards (25) Human resources for nuclear safety and nuclear emergency preparedness and response (26) Ensuring independence and diversity of safety systems (27) Effective use of probabilistic safety assessment (PSA) in risk management</p>
<p><i>Safety Culture</i></p>	<p>(28) Strong initiative to foster safety culture</p>



Evacuation of Residents



Fukushima Daiichi locates approximately

- 110 km from Tokai
- 230 km from Tokyo
- 580 km from Osaka
- 600 km from Sapporo

August 28, 2011




5640 - D

文部科学省 MINISTRY OF EDUCATION, CULTURE, SPORTS, SCIENCE AND TECHNOLOGY JAPAN

放射線量等分布マップ
- 航空機モニタリング -


凡例

地表面から1mの高さの
空間線量率($\mu\text{Sv} / \text{hr}$)
[8月28日現在の値に換算]





測定結果が得られていない範囲

— 計画的避難区域
— 緊急時避難準備区域



背景地図：電子国土

September 18, 2011




5640 - D

文部科学省 MINISTRY OF EDUCATION, CULTURE, SPORTS, SCIENCE AND TECHNOLOGY JAPAN

放射線量等分布マップ
- 航空機モニタリング -

凡例

地表面から1mの高さの
空間線量率($\mu\text{Sv} / \text{hr}$)
[9月18日現在の値に換算]





測定結果が
得られていない範囲

- 計画的避難区域
- 緊急時避難準備区域
(平成23年9月30日解除)

0 4 8 km

背景地図：電子国土

October 13, 2011




5640 - D

文部科学省 MINISTRY OF EDUCATION, CULTURE, SPORTS, SCIENCE AND TECHNOLOGY JAPAN

放射線量等分布マップ
- 航空機モニタリング -

凡例

地表面から1mの高さの
空間線量率($\mu\text{Sv} / \text{hr}$)
[10月13日現在の値に換算]





測定結果が
得られていない範囲

— 計画的避難区域
— 緊急時避難準備区域
(平成23年9月30日解除)

0 4 8 km

背景地図：電子国土

November 1, 2011




5640 - D

文部科学省 MINISTRY OF EDUCATION, CULTURE, SPORTS, SCIENCE AND TECHNOLOGY JAPAN

放射線量等分布マップ - 航空機モニタリング -

凡例


地表面から1mの高さの空間線量率 (μSv/h) [11月1日現在の値に換算]



測定結果が得られていない範囲



※本マップには天然核種による空間線量率が含まれています。

計画的避難区域 (緊急時避難準備区域 (平成23年9月30日解除))



背景地図：電子国土

November 5, 2011




5640 - D

文部科学省 MINISTRY OF EDUCATION, CULTURE, SPORTS, SCIENCE AND TECHNOLOGY JAPAN

放射線量等分布マップ - 航空機モニタリング -

凡例


地表面から1mの高さの空間線量率 (μSv/h) [2011年11月5日現在の値に換算]



測定結果が得られていない範囲



※本マップには天然核種による空間線量率が含まれています。

計画的避難区域 (緊急時避難準備区域) (平成23年9月30日解除)



背景地図：電子国土

May 31, 2012



5640 - D


文部科学省 MINISTRY OF EDUCATION, CULTURE, SPORTS, SCIENCE AND TECHNOLOGY JAPAN

放射線量等分布マップ
- 航空機モニタリング -

凡例

地表面から1mの高さの空間線量率 ($\mu\text{Sv}/\text{h}$)

[2012年5月31日現在の値に換算]





*本マップには天然核種による空間線量率が含まれています。

- 警戒区域
- 計画的避難区域
- 帰還困難区域
- 居住制限区域
- 避難指示解除準備区域 (2012年8月10日時点)

0 4 8 km

背景地図：電子国土

December 28, 2012




5640 - D

文部科学省
MINISTRY OF EDUCATION,
CULTURE, SPORTS,
SCIENCE AND TECHNOLOGY JAPAN

放射線量等分布マップ
- 航空機モニタリング -

凡例
地表面から1mの高さの空間線量率($\mu\text{Sv/h}$)
[2012年12月28日現在の値に換算]



測定結果が
得られていない範囲

積雪分布
(2012年11月1日~12月31日)

岩手県、宮城県、山形県、福島県、茨城県、栃木県、群馬県、千葉県を対象
JASMES: 宇宙航空研究開発機構 (JAXA)



* 本マップには天然核種による空間線量率が含まれています。
* 福島第一原子力発電所から80km圏内の測定結果は、2012年11月16日の結果を2012年12月28日現在の値に換算修正しています。風雨等の自然環境による放射性物質の移行の影響は考慮していません。
* 天候で覆われた白色の領域は積雪のあった箇所を表しており、当該地域及びその周辺における空間線量率は、雪の遮蔽により、雪が無い時に比べて減少している可能性があります。

- 警戒区域
- 計画的避難区域
- 帰還困難区域
- 居住制限区域
- 避難指示解除準備区域
(2012年12月10日時点)

0 4 8 km

背景地図: 電子国土


September 28, 2013



5640 - D

放射線量等分布マップ - 航空機モニタリング -

凡例
地表面から1mの高さの空間線量率($\mu\text{Sv/h}$)
[2013年9月28日現在の値に換算]





* 本マップには天然核種による空間線量率が含まれています。

- 帰還困難区域 (Red outline)
- 居住制限区域 (Green outline)
- 避難指示解除準備区域 (Blue outline)
(2013年8月8日時点)



背景地図: 電子国土



November 19, 2013



5640 - D


放射線量等分布マップ
- 航空機モニタリング -

凡例
地表面から1mの高さの空間線量率($\mu\text{Sv/h}$)
[2013年11月19日現在の値に換算]




- *1: 本マップには天然核種による空間線量率が含まれていません。
- *2: 福島第一原子力発電所から80km圏外の測定結果は、事故32か月(平成25年11月19日時点)の値に減衰補正、風雨時の自然環境による放射能物質の付着の影響は考慮していません。
- *3: 実施で取れた自治体の領域は黒色の点線を表示しています。

- 帰還困難区域
- 居住制限区域
- 避難指示解除準備区域 (2013年8月8日時点)



背景地図: 電子国土

Model for Decontamination and Waste Management



Recent Observations

Correlation between 2011/06 data and 2011/12 data

✓ Approximately 30% reduction in 6 months

• Observations

– Decrease by Radioactive Decay

- 17% decrease in 6 months

- Cs-134: Half life of 2 years

- Cs-137: Half life of 30 years


– Natural Dispersion

- 13%

- $\lambda=0.534 \text{ yr}^{-1}$

- Compare:

- $\lambda_S=0.05 \text{ yr}^{-1}$ (IAEA Safety series)



Effects of Decontamination and Natural Dispersion

Initial contamination (kBq/m ²)	Years to reach 20 mSv/yr				Years to reach 1 mSv/yr			
	No decontamination		With decontamination		No decontamination		With decontamination	
	Fast	Slow	Fast	Slow	Fast	Slow	Fast	Slow
> 3000	>1.43	>4.32	>1.10	>2.19	>5.67	>38.4	>4.25	> 9.83
1000 – 3000	0.90	2.52	0.70	1.36	5.06	32.8	3.81	8.62
600 – 1000	--	--	--	--	3.72	20.3	2.83	6.08
300 – 600	--	--	--	--	2.91	13.0	2.23	4.64
100 – 300	--	--	--	--	1.81	5.90	1.40	2.80
60 – 100	--	--	--	--	0.61	1.66	0.48	0.92

The goals set by the law:

- the annual dose is to be made less than 20 mSv/year within 2 years, and
- 1 mSv/year or lower at any location in the long term.

Fast: natural dispersion rate = 0.534 yr⁻¹



Slow: natural dispersion rate = 0.05 yr⁻¹

-- : air dose rates always below 20mSv/yr

Estimated Volume and Cost of Disposal for Radioactive Waste Arising from Decontamination

Initial soil contamination (kBq/m ²)	Area included (km ²)	Waste volume (million m ³)		Estimated cost (trillion yen)	
		<i>Fast dispersion</i>	<i>Slow dispersion</i>	<i>Fast dispersion</i>	<i>Slow dispersion</i>
> 3,000	183	5.6	8.1	3.6	5.3
1,000 – 3,000	368	10.5	15.7	6.8	10.2
Subtotal	551	16.1	23.8	10.5	15.5
600 – 1,000	282	6.6	10.5	4.3	6.8
300 – 600	721	14.1	23.2	9.2	15.1
Subtotal	1,003	20.7	33.7	13.5	21.9
Total	1,554	36.8	57.5	23.9	37.4

Time required for the air dose rate to become < 1 mSv/year



Summary of Fukushima Daiichi Nuclear Power Plant

	<i>Unit 1</i>	<i>Unit 2</i>	<i>Unit 3</i>	<i>Unit 4</i>	<i>Unit 5</i>	<i>Unit 6</i>
	BWR-3	BWR-4	BWR-4	BWR-4	BWR-4	BWR-5
PCV Model	Mark-I	Mark-I	Mark-I	Mark-I	Mark-I	Mark-II
Electric Output	460MWe	784MWe	784MWe	784MWe	784MWe	1100MWe
RPV Operation Pressure	6.89MPa	6.93MPa	6.93MPa	6.93MPa	6.93MPa	6.93MPa
RPV Max. Design Pressure	8.24MPa	8.24MPa	8.24MPa	8.24MPa	8.62MPa	8.62MPa
RPV Max. Operation Temp.	300°C	300°C	300°C	300°C	302°C	302°C
PCV Max. Design Pressure	384kPa	384kPa	384kPa	384kPa	384kPa	279kPa
PCV Max. Pressure *	427kPa	427kPa	427kPa	427kPa	427kPa	310kPa
PCV Max. Temp	140°C	140°C	140°C	140°C	138°C	171°C:D/W 105°C:S/C
Commercial Operation	1971.3.26	1974.7.18	1976.3.27	1978.10.12	1978.4.18	1979.10.24
Emergency DG	2	2 **	2	2 **	2	3 **
Electric Grid	275kV × 4				500kV × 2	
Plant Status on March 11, 2011	In Operation	In Operation	In Operation	Long Outage for Shroud Replacement	Refueling Outage	Refueling Outage

* Typical operating pressure of PCV is about 5 kPa.

** One Emergency DG is Air-Cooled **146**

Important Lessons Learned from Regulatory Points of View

- **Points to be addressed relevant to regulatory framework**
 - Enhancement of **Defense-in-Depth**
 - **Diversity, Flexibility and Operability** of Measures against Severe Accidents
 - Enhancement of **Consistency with International Standards and Practices**

- **Lessons learned as a regulatory organization**
 - **Lack of System Perusing Safety Enhancement**
 - **Needs for Feedback of Latest Knowledge and Findings, etc.**

Important Lessons Learned (1/2)

■ Design Basis Tsunami:

- DB-Ts was re-evaluated in 2002, but was seriously underestimated.
- New information such as Jyogan Tsunami (869) was not thoroughly considered.

⇒ Continuous efforts to **reduce uncertainty of external hazard** were needed.

■ Beyond Design Basis Tsunami :

- We should have been prepared for **Design Basis Tsunami being exceeded**. Such a risk exists even if the best efforts are made to determine DB-Ts. (preparation for “**Low likelihood, high consequence**” events)

⇒ Protection against **dynamic force** of tsunami, **water tightness** of doors, **diversity in layout** of equipment, etc., were needed to **prevent common cause failures (CCFs)**.

■ Protection against Severe Accidents (SAs):

- **Accident management (AM) measures** implemented against SAs were not effective. No AM measures had been taken for **spent fuel pools (SFPs)**

Important Lessons Learned (2/2)


■ **Emergency Preparedness and Responses:**

- Improvement of preparedness (communication, resources, etc.) assuming **combination of large-scale natural disasters and prolonged nuclear accident.**
- Enhancement of **environmental monitoring** for emergency
- Clarification of roles / responsibilities **between central and local organizations**
- many others

■ **Strengthening of Safety Culture:**

- We need to ask ourselves:
 - ✓ Were we vigilant enough to the plant vulnerabilities?
 - ✓ Were we careful enough for new technical findings?
- **There's no “continuous improvement of safety” without “safety culture”.**

Nuclear Power Plants in Japan



Effects of Ageing in the Fukushima Accident ?

- **As the results of the evaluation based on the knowledge obtained so far, it is quite unlikely that there was an effect of ageing degradation on loss of functions in SSCs important to safety due to the ground motion by the earthquake.**
- **It is also unlikely that ageing degradation phenomena have caused the occurrence and enlargement of the Fukushima Daiichi accident.**
- **However, as it is difficult to confirm the status of equipment at this moment, additional investigation will be needed, when new knowledge is obtained in the future.**

**Report of the Expert Meeting on Ageing Management in NISA
(February 7, 2012)**

Evaluation of Additional Effect of the Earthquake on Low Cycle Fatigue of Main Steam Line Piping of Unit 1

Cumulative Fatigue Coefficient for 60 years	Fatigue Coefficient considering Earthquake		
	Due to Seismic Load		Total
0.064	S_2	0.252	0.316
	S_s	0.269	0.333
	Earthquake on March 11, 2011	0.264	0.328

Equivalent number of cycle due to seismic load is conservatively assumed to be 100.
 S_2 , S_s : Design basis seismic ground motion

Evaluation of Effect of the Earthquake on March 11, 2011 on Structural Integrity of Important Pumps considering General Corrosion of Anchor Bolts



	Pumps Evaluated	Shear Stress [MPa]		Allowable Stress [MPa]
		Without Corrosion	With Corrosion for 60 years	
Unit 1	Reactor Shut Down Cooling System Cooling Pumps	8	9	127
Unit 2	Residual Heat Removal System Pumps	34	36	202
Unit 3	Residual Heat Removal System Pumps	23	24	202

- The corrosion of the anchor bolts was evaluated by multiplication of cross-section decrease rate (6.0%/y) in consideration of the corrosion amount for 60 years of 0.3 mm.
- The shear stress with consideration of the amount of corrosions for 60 years was confirmed that there was sufficient margin to the allowable stress.

Macroscopic Balance between Decay Heat and Heat Removal in Unit 1

Decay Heat > Heat Removal


- Total decay heat before sea water injection greatly exceeds the amount of heat which reactor water and structural materials could absorb.
- All molten core moved to RPV bottom and they damaged RPV and run down to PCV.




Reactor Water Level and Core Temperature in Unit 1

- *Simulation Trial by the MAAP code -*

Assuming that IC lost its function by the Tsunami



- reached top of active fuel in 3 hours (around 18:00) after the scram
- reached bottom of active fuel in 4 and a half hours (around 19:30) after the scram



The core temperature started increasing when the reactor water level became lower than top of active fuel, then reached the core melting temperature.

Failure of Power Supply and Cooling Systems

The reactors shut down automatically due to the **Earthquake**, loss of external power supply.

Power supply equipment such as D/Gs was not unavailable due to the **Tsunami**, loss of all AC power supply

Units 1 & 2

Loss of function of DC power supply due to the **Tsunami**

Unit 3

Function of DC power supply maintained

Unit 1

IC was unavailable to check status and operate. HPCI was unavailable to start up.

Unit 2

RCIC continued cooling.

Unit 3


RCIC or HPCI continued cooling until battery ran out.

Led to accident at early time

RCIC continued to operate until 13:25 on March 14.

After RCIC stopped at 11:36 on March 12, HPCI started up automatically due to low level of water in reactor.

Fission Products



- More than 30 chemical elements are produced by fission reaction
- Chemical state of fuel can evolve substantially during burn-up
- 20-25% of fission products are gas atoms (Kr, Xe)

Groups of Radionuclides from Nuclear Fuel

<i>Group #</i>	<i>Designation</i>	<i>Elements</i>
1	Noble Gases	Xe, Kr
2	Halogens	I, Br
3	Alkali Metals	Cs, Rb
4	Tellurium Group	Te, Sb, Se
5	Barium, Strontium	Ba, Sr
6	Noble Metals	Ru, Rh, Pd, Mo, Tc, Co
7	Lanthanides	La, Zr, Nd, Eu, Nb, Pm, Pr, Sm, Y, Cm, Am
8	Cerium Group	Ce, Pu, Np

Radionuclides considered Important in the Reactor Safety Study Consequence Analysis (1)

3,200 MWth PWR case

Radionuclides	Half-life [days]	Shutdown inventory [MCi]
1) Noble gases		
⁸⁵ Kr*	3950	0.56
^{85m} Kr*	0.183	24
⁸⁷ Kr*	0.0528	47
⁸⁸ Kr*	0.117	68
¹³³ Xe	5.28	170
¹³⁵ Xe	0.384	34
2) Halogens		
¹³¹ I	8.05	85
¹³² I	0.0958	120
¹³³ I	0.875	170
¹³⁴ I	0.0366	190
¹³⁵ I	0.28	150
3) Alkali metals		
¹³⁴ Cs	750	7.5
¹³⁶ Cs	13	3
¹³⁷ Cs	11000	4.7
⁸⁶ Rb*	18.7	0.026

4) Tellurium group		
¹²⁷ Te*	0.391	5.9
^{127m} Te	109	1.1
¹²⁹ Te*	0.048	31
^{129m} Te	0.34	5.3
^{131m} Te	1.25	13
¹³² Te	3.25	120
¹²⁷ Sb	3.88	6.1
¹²⁹ Sb	0.179	33
5) Barium and strontium group		
⁸⁹ Sr	52.1	94
⁹⁰ Sr	11030	3.7
⁹¹ Sr	0.403	110
¹⁴⁰ Ba	12.8	160

*** Indicates negligible contribution to health effects**

Radionuclides considered Important in the Reactor Safety Study Consequence Analysis (2)

Radionuclides	Half-life [days]	Shutdown inventory [MCi]
6) Noble metals		
⁵⁸ Co*	71	0.78
⁶⁰ Co*	1920	0.29
⁹⁹ Mo	2.8	160
^{99m} Tc*	0.25	140
¹⁰³ Ru	39.5	110
¹⁰⁵ Ru*	0.185	72
¹⁰⁶ Ru	366	25
¹⁰⁵ Rh*	1.5	49


3,200 MWth PWR case

*** Indicates negligible contribution**


7+8) Lanthanides and cerium group		
⁹⁰ Y*	2.67	3.9
⁹¹ Y	59	120
⁹⁵ Zr	65.2	150
⁹⁷ Zr	0.71	150
⁹⁵ Nb	35	150
¹⁴⁰ La	1.67	160
¹⁴¹ Ce	32.3	150
¹⁴³ Ce*	1.38	130
¹⁴⁴ Ce	284	85
¹⁴³ Pr	13.7	130
¹⁴⁷ Nd*	11.1	60
²³⁹ Np	2.35	1640
²³⁸ Pu	32500	0.057
²³⁹ Pu	8.90E+06	0.021
²⁴⁰ Pu	2.40E+06	0.021
²⁴¹ Pu	5350	3.4
²⁴¹ Am*	1.50E+05	0.0017
²⁴² Cm	163	0.5
²⁴⁴ Cm	6630	0.023

Examples of Decay Chains containing Cs from Fission Reaction of ^{235}U by Thermal Neutrons


133



135



137



Fission Gas Yield

Isotopes	²³⁵ U	²³⁹ Pu
⁸³ Kr	0.40	0.30
⁸⁴ Kr	0.85	0.50
⁸⁵ Kr	0.15	0.13
⁸⁶ Kr	1.40	0.80
Total Kr	2.8	1.7
¹³¹ Xe	3.2	3.8
¹³² Xe	4.7	5.3
¹³⁴ Xe	6.6	7.5
¹³⁶ Xe	5.9	6.6
Total Xe	20.4	23.2

- Minor actinides (Am, Cm) also produce significant quantities of He during further irradiation by (n,α) reaction


Tsunami on March 11, 2011



Source: TEPCO


Mark-I and Mark-II Primary Containment Vessel (6 BWR Units in Fukushima Daiichi)

***Unit 1
(Mark-I)***




460 MWe

***Units 2,3,4 and 5
(Mark-I)***



784 MWe


Unit 6 (Mark-II)



1,100 MWe


- Volume of Mark-II containment vessel is larger than that of Mark-I.
- Units 1-3 were operating at the time of the Earthquake.
- Unit 4-6 were in refueling outage

BWR with Mark-I Type Containment Vessel (Fukushima Daiichi, Units 1,2,3,4 and 5)





The Main Shock (and Aftershocks) of the Earthquake on March 11, 2011

March 11 to May 13, 2011



Tsunami after the Earthquake on March 11, 2011




Tsunami on March 11, 2011


Fukushima Daiichi



Fuel Rods, Fuel Assemble and Core of BWR



Fuel Assembly



Fuel Rod



Cladding tubes (Zirconium alloy)



1 cm



UO₂ pellet



Fuel Assemblies in the Core : 400 in Unit 1

548 in Units 2 and 3


Macroscopic Balance

between Decay Heat and Heat Removal in Unit 1

- Total decay heat before sea water injection greatly exceeds the amount of heat which reactor water and structural materials could absorb.
- Oxidation reaction of Zr provides additional heat to promote the core damage.
- All molten core moved to RPV bottom and they damaged RPV and run down to PCV.



Detection of Neutrons



- Neutrons detected in the morning of March 13 and in the night of March 14 were released in the course of fuel melting at Units 3 and 2, respectively.
- Neutrons may have been generated by the spontaneous fission of released actinides.

Radiation Control for Site Workers

Radiation Dose from External and Internal Exposure for Workers in Fukushima Daiichi Nuclear Power Station


3,695 Workers (working from March) and 3,388 Workers (from April) *
have been inspected by July 29, 2011

Radiation Dose (External + Internal): Number of Workers

100mSv ~ 150mSv	:	86
150mSv ~ 200mSv	:	14
200mSv ~ 250mSv	:	2
250mSv ~	:	6
		(309mSv ~ 678mSv)

* out of total workers 3,747(from March) + 3,776 (from April)

Radiation Monitoring at The University of Tokyo From March 15 to 31, 2011




Distance from Fukushima Daiichi NPPs

Ibaraki, Tokai Campus : 110 km


Tokyo, Hongo Campus : 230 km

Radiation Monitoring at The University of Tokyo

From March 15 to May 24, 2011



Monitoring Radiation Dose in Fukushima Prefecture



Source: MEXT press release

Defense in Depth (1)

Approach and Lessons Learned

- Key issues to be addressed in Fukushima Daiichi NPS accident
(Lack of flexible response to unanticipated events)
 - Level 1 (Prevention of abnormal operation): Simultaneous functional loss of many safety components by tsunami/external event
=> Protection against external event
 - Level 2 (Control of abnormal operation): Scramming, activation of EDGs
 - Level 3 (Mitigation of effects): Failure of engineered safety SSCs due to total power loss.
 - Level 4 (Accident Management): Failed due to severe conditions such as loss of total power
and high radiation dose
=> Effectiveness and reliability of AM

5.4 (2) Accident Management

Basic Approach on the Development of Accident Management

- Strategy on organization of accident management (AM)
Since accident management concerns effectively controlling event progression and managing accident recovery, safety must be ensured by combining measures on both tangible/hardware (SSCs) aspects and intangible/human aspects (education & training, procedure manuals, organization).
- AM on hardware/tangible aspects
Effective use of not only safety margin and engineered safety features in the design, but possible use of other functions beyond their originally intended function, and provisions as new installation of SSCs to respond to accident conditions, etc.
- AM on tangible/human aspects
Because accident management depends largely on the actions and manipulations by the operating staff, it should include both tangible/hardware aspects (e.g., improvement of SSCs) and intangible/human aspects such as development of education & training, organization, procedures & guidelines manuals.

Failure of Containment Functions of PCV

(1) Leakage path for Gaseous radioactive material


- Likelihood of leaks from PCV penetrations, hatch, and silicon rubber seals of PCV upper flange (200 centigrade heat resistant)
- Need to confirm leak points by conducting onsite surveys

(2) Contaminated water leaks

- Damages in the lower part of PCV, from where contaminated water is assumed to have leaked via the turbine building.
- Verified leaks from part of vent pipe in Unit 1. (Nov. 2012, report by TEPCO)
- Need to reduce leak events

(3) Requires provisions for PCV rupture caused by over-pressure and over-heat

- PCV cooling via containment spray and safeguards against over-pressure via filtered vents;
- safeguards against damages on the lower pedestal of PCV (e.g., coolant injection to PCV pedestal, etc.).



Loss of Power Supply in Units 1-4

Loss of the External Power Supply


Breakers were broken due to the earthquake

Okuma 3L : Under modification

Loss of all the EDG Functions either by

- 1) Damage in Generator
- 2) Loss of Sea-Water Cooling System
- 3) Damage at Power Panels by the Tsunami flood

Loss of DC Battery except for Unit 3



(EDG : Emergency Diesel Generator)

* Recovery of Off-site Power Supply

Unit 2 on March 20, Units 1,3 and 4 on March 22

One Air-Cooled DG (DG6B) survived in Units 5 & 6


Loss of Off-site Power Supply

- Collapse of Pylons by the Earthquake



Survival of One Air-Cooled Diesel Generator

Survival of DC Battery



Damage in sea-water cooled EDGs by the Tsunami

* Recovery of Off-site Power Supply on March 20-21

Photographs from One of the Fukushima 50



Source: TEPCO

- **After the Tsunami,**
 - **No lighting available**
 - **What they can get are flashlights, batteries (some are removed from automobiles), fire trucks and some compressors**
 - **Very difficult to measure the major safety parameters like water level, reactor pressure, CV pressure**
 - **No communication tools between the Emergency Response Room and workers at the field**